



# 中国国家强制性产品认证证书

证书编号：2024010303693579

## 认证委托人名称及地址

Carlo Gavazzi Automation SpA  
Via Milano, 13 20020-Lainate (MI)-Italy

## 生产者名称及地址

Carlo Gavazzi Controls SPA  
Via Safforze, 8, 32100 BELLUNO Italy

## 生产企业名称及地址

Carlo Gavazzi Controls SPA  
Via Safforze, 8, 32100 BELLUNO Italy

## 产品名称和系列、型号、规格

电压继电器、电流继电器  
DUB01、DIB01；详见附页

## 产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年09月18日 有效期至：2029年09月17日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，  
也可在认监委网站（[www.cnca.gov.cn](http://www.cnca.gov.cn)）查询。



签发：

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010303693579

证书附页：第 1 页 共 1 页

DUB01、DIB01

Ui:300V;

Uimp:4kV;

Ith:8A;

AC-15:Ue/Ie:AC250V/2.5A;

DC-13:Ue/Ie:DC24V/2.5A;

DC-12:Ue/Ie:DC24V/5A;

IP20

## 型号解释:

D (x) B01C (y) (z) (w)

(x) Input type/输入类别:

U: Voltage

I: Current

(y) Operational voltage/运行电压:

B23: 115/230VAC 50-60Hz

D48: 24-48VAC/DC 50-60Hz

M24: 24-240VAC 50-60Hz 24VDC

(z) Input range/输入范围:

10V: voltage 10V

500V: voltage 500V

10A: current 10A

5A: current 5A

5MA: current 5mA

50MA: current 50mA

500MA: current 500mA

100A: current 100A

(w) optional alphanumerical characters indicating cosmetic or firmware variations, not affecting safety

可选字母或数字，代表装饰或软件不同，不影响安全性能

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010303693579

**NAME AND ADDRESS OF THE APPLICANT**

Carlo Gavazzi Automation SpA  
Via Milano,13 20020-Lainate(MI)-Italy

**NAME AND ADDRESS OF THE MANUFACTURER**

Carlo Gavazzi Controls SPA  
Via Safforze,8,32100 BELLUNO Italy

**NAME AND LOCATION OF THE FACTORY**

Carlo Gavazzi Controls SPA  
Via Safforze,8,32100 BELLUNO Italy

**PRODUCT NAME,MODEL AND SPECIFICATION**

Voltage relay, 3-phase Relay  
DUB01、 DIB01 ; See the Appendix

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Sep.18,2024

**Valid until:** Sep.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010303693579

Appendix : Page 1 of 1

DUB01、DIB01

Ui:300V;

Uimp:4kV;

Ith:8A;

AC-15:Ue/Ie:AC250V/2.5A;

DC-13:Ue/Ie:DC24V/2.5A;

DC-12:Ue/Ie:DC24V/5A;

IP20

## Type explanation :

D (x) B01C (y) (z) (w)

(x) Input type/输入类别:

U: Voltage

I: Current

(y) Operational voltage/运行电压:

B23: 115/230VAC 50-60Hz

D48: 24-48VAC/DC 50-60Hz

M24: 24-240VAC 50-60Hz 24VDC

(z) Input range/输入范围:

10V: voltage 10V

500V: voltage 500V

10A: current 10A

5A: current 5A

5mA: current 5mA

50MA: current 50mA

500MA: current 500mA

100A: current 100A

(w) optional alphanumerical characters indicating cosmetic or firmware variations, not affecting safety

可选字母或数字，代表装饰或软件不同，不影响安全性能

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.