



中国国家强制性产品认证证书

证书编号：2024010303693572

认证委托人名称及地址

Carlo Gavazzi Automation SpA
Via Milano, 13 20020-Lainate (MI)-Italy

生产者名称及地址

Carlo Gavazzi Controls SPA
Via Safforze, 8, 32100 BELLUNO Italy

生产企业名称及地址

Carlo Gavazzi Controls SPA
Via Safforze, 8, 32100 BELLUNO Italy

产品名称和系列、型号、规格

三相继电器

DPC01; 详见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年09月18日 有效期至：2029年09月17日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010303693572

证书附页: 第 1 页 共 1 页

DCP01
Ui:600V;
Uimp:6kV;
Ith:8A;
AC-15:Ue/Ie:AC250V/2.5A;
DC-13:Ue/Ie:DC24V/2.5A;
DC-12:Ue/Ie:DC24V/5A;
IP20

型号解释:

DPC01D (x) (y) (z)

(x) Operational voltage: 运行电压

M11: 100/115 VAC;

M23: 208/240 VAC;

M44: 208-690 VAC;

M48: 380/480 VAC; (M48 400HZ: 380/415 VAC)

M49: 440/480 VAC;

M69: 600/690 VAC;

(y) Operational frequency: 运行频率

nil: 50-60Hz (for M44 model 50-400Hz)

400HZ: 50-400Hz

(z) optional alphanumerical characters indicating cosmetic or firmware variations, not affecting safety

可选字母或数字, 代表装饰或软件不同, 不影响安全性能。

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010303693572

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Automation SpA
Via Milano,13 20020-Lainate(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

NAME AND LOCATION OF THE FACTORY

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

PRODUCT NAME,MODEL AND SPECIFICATION

3-phase Relay
DPC01 ; See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.18,2024

Valid until: Sep.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010303693572

Appendix : Page 1 of 1

DCP01

Ui:600V;

Uimp:6kV;

Ith:8A;

AC-15:Ue/Ie:AC250V/2.5A;

DC-13:Ue/Ie:DC24V/2.5A;

DC-12:Ue/Ie:DC24V/5A;

IP20

Type explanation :

DPC01D (x) (y) (z)

(x) Operational voltage:运行电压

M11: 100/115 VAC;

M23: 208/240 VAC;

M44: 208-690 VAC;

M48: 380/480 VAC; (M48 400HZ: 380/415 VAC)

M49: 440/480 VAC;

M69: 600/690 VAC;

(y) Operational frequency:运行频率

nil: 50-60Hz (for M44 model 50-400Hz)

400HZ: 50-400Hz

(z) optional alphanumerical characters indicating cosmetic or firmware variations, not affecting safety
可选字母或数字，代表装饰或软件不同，不影响安全性能。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.