

Certificate of Compliance

Certificate: 2352057 Master Contract: 151025

Project: 70010309 **Date Issued:** August 21, 2014

Issued to: Carlo Gavazzi Industri A/S

Over Hadstenvej 40 Hadsten, 8370 Denmark

Attention: Morten Steen Jensen

The products listed below are eligible to bear the CSA Mark shown



Omar Elouadrhírí

Issued by: Omar Elouadrhiri

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Conductive Systems with potentiometers, open type, model CL followed by P or D, followed by 1, 2 or 4, followed by E, F or M, followed by A or B, followed by 1 or 2, followed by A, B, C or D, followed by M24, 024, 724, 115 or 230, may be followed by 1 - 9. Rated as follow: Input: 24Vdc or 24 or 115 or 230 Vac, 50/60 Hz. One or two Output relay 8A/250Vac type SPST or SPDT or DPDT

Notes:

• Component open type for factory installation only where the suitability has to be evaluated by CSA International in the final assembly.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No 14-13 - Industrial Control Equipment

DQD 507 Rev. 2012-05-22 Page: 1