



# Certificate of Compliance

**Certificate:** 1241432

**Master Contract:** 168390

**Project:** 2279385

**Date Issued:** 2010/03/12

**Issued to:** Carlo Gavazzi Controls S.p.A.

Via Safforze 8

Belluno, 32100

Italy

Attention: Alberto Mambrini

*The products listed below are eligible to bear the CSA Mark shown*



*Omar Elouadrhiri Eng*

**Issued by:** Omar Elouadrhiri Eng

## **PRODUCTS**

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Multifunction Monitoring Relays, input max 600V, output contact max 250 Volts 8 Amp., Models DPB, PPB, DPC, PPC, DIB, PIB, DIC, PIC, DUB, PUB, DUC, PUC, DFB, PFB.

Notes:

1. Suffixes may be added to specific options.
2. Component open type for factory installation only where the suitability has to be evaluated by CSA International in the final assembly.

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment