

Certificate of Compliance

Certificate:	1251200
Continueuro	1201200

Project: 2002075

Issued to: Carlo Gavazzi Ltd.

BLB042 Bulebel Industrial Estate Zejtun ZTN3000, Malta Attention: na Master Contract: 204075

Date Issued:

2008/03/20

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Omar Elouadrhiri, Jr. Eng.

Authorized by: Helene Vaillancourt, Operations Manager

Hetin Vaillawout

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Double phase zero switching solid state relays, Model RA2A Series max 600 Volts, 40 Amp in pollution degree 2 environment.

Note: Component type relays where the suitability must be re-evaluated in the final assembly by CSA International.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment