

CERTIFICATE OF COMPLIANCE

Certificate Number 20190313-E163113
Report Reference E163113-19951016
Issue Date 2019-MARCH-13

Issued to: CARLO GAVAZZI INDUSTRI A/S
Over Hadstenvej 40
8370 Hadsten DENMARK

**This certificate confirms that
representative samples of**

PROXIMITY SWITCHES
Capacitive Proximity Switches (Sensor) with cable or plug
connection
EC18, EC30, EC55, CA12, CA18, CA30, CB18, CB30,
CD46, VC55, may be followed by suffixes.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL508 and CSA C22.2 NO. 14-13, STANDARD FOR
INDUSTRIAL CONTROL EQUIPMENT

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

