

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130301-E163113  
**Report Reference** E163113-20101218  
**Issue Date** 2013-MARCH-01

**Issued to:** CARLO GAVAZZI INDUSTRI A/S  
OVER HADSTENVEJ 40  
8370 HADSTEN DENMARK

**This is to certify that  
representative samples of**

PROXIMITY SWITCHES

Listed Photo Electric Proximity Switches, Cat. Nos:  
PA18CA, followed by D, R, P or T, followed by 04, 10, 20,  
50 or 65, may be followed by NA or PA, may be followed by  
M1, may be followed by SA, WS or IS.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL508 and CSA C22.2 No. 14-10,  
Industrial Control Equipment

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

