



Certificate of Compliance

Certificate: 1781820

Master Contract: 168390

Project: 70105849

Date Issued: 2017-01-31

Issued to: Carlo Gavazzi Controls S.p.A.
Via Safforze 8
Belluno 32100
ITALY
Attention: Alberto Mambrini

The products listed below are eligible to bear the CSA Mark shown



Issued by: Marilyn Laroche
Marilyn Laroche, P.Eng

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

These devices are electronic–solid state timer relays, called E-Family Mini Timer Series.

Component, Mini Timer Series E followed by letter A or B, followed by letter S, followed by letter S, followed by M23, followed by 10S, 1M or 10M, may be followed by F.

Component, Mini Timer Series E followed by letter C, followed by letter S, followed by letter S, followed by M23, followed by A or B, followed by 10S, 1M or 10M, may be followed by F.

Rating input maximum: 230Vac/dc; Output: 0.7A

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No.0-10	-	General Requirements – Canadian Electrical Code, Part II
CSA C22.2 No. 14-13	-	Industrial Control Equipment



Certificate: 1781820
Project: 70105849

Master Contract: 168390
Date Issued: 2017-01-31

Supplement to Certificate of Compliance

Certificate: 1781820

Master Contract: 168390

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1781820	2006-06-21	New certification, Model ExS.
70105849	2017-01-31	Update report 1781820 to cover the addition of alternative plastic material specific to the Mini Timer Series included in this report under CAN/CSA C22.2 No.0-10 and CSA C22.2 No. 14-13